



TYPICAL ISOLATION JOINT SEAL  
(LONGITUDINAL AND TRANSVERSE)

**NOTES:**

1. ALL CONCRETE SHALL MEET CURRENT NDDOT SPECIFICATIONS, UNLESS NOTED OTHERWISE.
2. CONCRETE SHALL HAVE A 28 DAY COMPRESSIVE STRENGTH OF 4,000 PSI MINIMUM.
3. REBAR SHALL BE TIED WITH WIRE AND BE SUPPORTED WITH PROPER REBAR "CHAIRS".
4. JOINTS SHALL BE SAW CUT AT 4' SPACING AT A DEPTH OF 1". SAWING SHALL BE DONE DURING THE SAME WORKING DAY THAT THE CONCRETE IS POURED.
5. CURE COMPOUND SHALL BE IMMEDIATELY APPLIED AFTER POUR. CONCRETE SHALL BE FULLY COVERED BY CURE COMPOUND.
6. ISOLATION JOINT SHALL BE INSTALLED AT ALL CONNECTIONS TO EXISTING CONCRETE AND @ 150' MAXIMUM SPACING.
7. ISOLATION JOINTS SHALL NOT BE TIED WITH REBAR, BUT SHALL UTILIZE GREASED 18" LONG 1/2" SMOOTH DOWELS

082715.08.31.53A.M.2:Project\Drawings\Reiles Acres\_Sidewalk Detail.dwg



3330 FIECHTNER DRIVE - SUITE 102  
FARGO, NORTH DAKOTA 58103

**SIDEWALK DETAIL  
REILE'S ACRES,  
NORTH DAKOTA**



LE JOB #	15016
PROJECT DATE:	08/27/2015
DRAWN BY:	RJW
APPROVED BY:	AJT
SHEET:	1 OF 1

**DETAIL**